

WATER WELL REPORT

STATE OF WASHINGTON

31/02-29E 61-20899

Permit No. 61-20899F

(1) OWNER: Name LEWIS B. MEADORS JR Address Rt#1 Box 230 COUPEVILLE, WASH
(2) LOCATION OF WELL: County ISLAND N $\frac{1}{2}$ SW $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. 29 T. 31 N. R. 2E W.M.
Bearing and distance from section or subdivision corner 400 FT EAST 840' N of W $\frac{1}{4}$ corner Sec 29

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☒ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one)
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☐ Driven ☒
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 130 ft. Depth of completed well 120' 2" ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 109' 1" ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☒ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒

Type of perforator used
SIZE of perforations in. by in.
..... perforations from ft. to ft.
..... perforations from ft. to ft.
..... perforations from ft. to ft.

Screens: Yes ☒ No ☐

Manufacturer's Name JOHNSON
Type STAINLESS STEEL Model No.
Diam. 6" Slot size 10 from 109 ft. to 120 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☒ Size of gravel:
Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? 29 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: TO BE INSTALLED LATER

Manufacturer's Name HP 3

(8) WATER LEVELS: Land-surface elevation 315 ft.
Static level 66' 6" ft. below top of well Date 2-10-74
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom? DRILLER
Yield: 30 gal./min. with 15 ft. drawdown after 1 hrs.
" 304 PM " " " " " " " " " " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level
11:00	68'	11:15	66' 6"		

Date of test 2-10-74
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☐ No ☒

(10) WELL LOG:

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
TOP SOIL	0	6
HARD PAN WITH ROCKS	6	28
ROCK DRILLED THROUGH IT	28	29
HARD PACKED SAND GRAY	29	38
SAND WITH CLAY BROWN	38	81
SAND FINE WITH WATER GRAY	81	102
SAND COARSE WITH WATER	102	120
SAND & CLAY BROWN DRY	120	130

PULLED BACK TO 120'
SET TWO #10 SCREENS
DEVELOPED WELL & TEST
PUMP.

Work started FEB 1, 1974. Completed FEB 10, 1974

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME BOB DRILLING CO
(Person, firm, or corporation) (Type or print)

Address P.O. Box 55 FREELAND WA 98241

[Signed] W.C. Lehman
(Well Driller)

License No. 223-02-7416 Date 3-10, 1974
Ecology 0265

(USE ADDITIONAL SHEETS IF NECESSARY)